



# Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows  
 Rollläden · shutters  
 Türen + Tore · doors  
 Fassaden · curtain walling  
 Baubeschläge · building hardware


## TEST CERTIFICATE NO. 18/03-A001-Z1

Version 1.en

PfB-Internal-No. 18/04-A156

Sound Insulation calculation according EN 14351-1 : 2006 + A2 : 2016 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets”

**Applicant** Deceuninck TR  
 MPIO SB Atatürk Plastik OSB Mah. 5.Cad. No:4  
 Menemen - İzmir  
 Türkiye



**Product type** Single leaf sliding door with fixed glazing side part, PVC

**Product name** Sliding

**Glazing** 6-16-8,4 /  $R_w$  (C; Ctr) = 39 (-1, -5) dB

**Dimension** Total outside dimensions (W x H) max. 2000 mm x 2200 mm

**Classification** According to test report No. 18/03-A001-B1 from April 03, 2018:

Size of Specimen	Double glazing	4 - 16- 8.4
Area $\leq 2,7 \text{ m}^2$	$R_w$ (C;Ctr) dB	<b>37 (-1;-4)</b>
$2,7 \text{ m}^2 \leq \text{Area} \leq 3,6 \text{ m}^2$	$R_w$ (C;Ctr) dB	<b>36 (-1;-4)</b>
$3,6 \text{ m}^2 \leq \text{Area} \leq 4,6 \text{ m}^2$	$R_w$ (C;Ctr) dB	<b>35 (-1;-4)</b>
Area $> 4,6 \text{ m}^2$	$R_w$ (C;Ctr) dB	<b>34 (-1;-4)</b>

**Validity** Period of validity of EN 14351-1 : 2006 + A2 : 2016

  
 Dipl. Ing. (FH) Rüdiger Müller  
 Head of Institute

  
 Stephanskirchen  
 April 03, 2018

  
 Yiğit Altuğ  
 Responsible Official